

# EG-declaration of conformity

**TECKENTRUP**  
DOOR SOLUTIONS

**Manufacturer:** Teckentrup GmbH & Co. KG  
Industriestraße 50  
D-33415 Verl-Sürenheide

**Product:** doors for private and/or industrial use  
Teckentrup fire rated sliding doors

- Fire rated sliding door E, EW, EI<sub>2</sub>30-62 FST
- Fire rated sliding door E, EW, EI<sub>2</sub>90-62 FST
- sliding door S200-62 FST

## The applied directives and harmonized norm:

EN 16034	Fire resistance and/or smoke characteristics
EN 13241	Product standard, performance characteristics
EN 12604	Doors- mechanical Aspects - requirements and test methods
EN 12453	Doors- safety in use of power operated doors - requirements and test methods
EN 12635	Doors- installation and use
305/2011	EG- construction products regulation

## Additional doors with motor:

2006/42/EG	EG – directive for machinery
2014/35/EU	Directive for low voltage
2014/30/EU	EMV - directive

## Certificated motors for a.m. doors:

Schnetz	ATS – 300 – MOF(E) – SVR – 538
	ATS – 400 – MOF – SVR – 538
	ATS – 900 – MOF – SVR – 538

## Notified centre for tests and certification:

Tüv Nord Cert GmbH, Langemarckstraße 20, DE-45141Essen  
DMT-Prüflaboratorium für Brandschutz, Tremoniastraße 13, DE-44137 Dortmund

**Place, Date:** D-33415 Verl-Sürenheide, den 01.03.2022



**Person in charge of the documentation:** .....

Kai Teckentrup, general management of Teckentrup GmbH & Co. KG